

UKCA DECLARATION OF CONFORMITY No. UKCA 23.3657.12.23

We Hager LTD
Hortonwood 50
TELFORD-TF1 7FT-UK

Declare that the product(s)

Designation

Enclosed LBS

Type reference(s)

JA**** Range

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN IEC 60947-3:2021

BS EN IEC 60947-1:2021

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager LTD

Name of signatory

Ian Ellis

Function of signatory

Certification Manager (Enclosure Systems)

Place and date of issue

Telford, UK 21/12/2023

Signature

Ian Ellis

UKCA DECLARATION OF CONFORMITY

No. UKCA 23.3657.12.23

Type references

Product Reference	Product Description
JAB302	Enclosed Switch Disconnecter TPN 20A
JAB402	Enclosed Switch Disconnecter TPSN 20A
JAB303	Enclosed Switch Disconnecter TPN 32A
JAB403	Enclosed Switch Disconnecter TPSN 32A
JAB304	Enclosed Switch Disconnecter TPN 40A
JAB404	Enclosed Switch Disconnecter TPSN 40A
JAB306	Enclosed Switch Disconnecter TPN 63A
JAB406	Enclosed Switch Disconnecter TPSN 63A
JAB310	Enclosed Switch Disconnecter TPN 100A
JAB410	Enclosed Switch Disconnecter TPSN 100A
JAC312	Enclosed Switch Disconnecter TPN 125A
JAC412	Enclosed Switch Disconnecter TPSN 125A
JAC316	Enclosed Switch Disconnecter TPN 160A
JAC416	Enclosed Switch Disconnecter TPSN 160A
JAE320	Enclosed Switch Disconnecter TPN 200A
JAE420	Enclosed Switch Disconnecter TPSN 200A
JAE325	Enclosed Switch Disconnecter TPN 250A
JAE425	Enclosed Switch Disconnecter TPSN 250A
JAG331	Enclosed Switch Disconnecter TPN 315A
JAG431	Enclosed Switch Disconnecter TPSN 315A
JAG340	Enclosed Switch Disconnecter TPN 400A
JAG440	Enclosed Switch Disconnecter TPSN 400A
JAH363	Enclosed Switch Disconnecter TPN 630A
JAH463	Enclosed Switch Disconnecter TPSN 630A
JAH380	Enclosed Switch Disconnecter TPN 800A
JAH480	Enclosed Switch Disconnecter TPSN 800A
JAH390	Enclosed Switch Disconnecter TPN 1250A
JAH490	Enclosed Switch Disconnecter TPSN 1250A
JAH392	Enclosed Switch Disconnecter TPN 1600A
JAH492	Enclosed Switch Disconnecter TPSN 1600A

UKCA DECLARATION OF CONFORMITY

No. UKCA 23.3657.12.23

Evidence(s)

Documents listed below have been developed to assure that all essential requirements of applied directive(s) are fulfilled:

If the product is not in the scope of Radio Equipment directive, fulfil table 1a, if yes fulfil table.

Table 1a Risk Assessment for Equipment without Radio		Applicable:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used:	Yes BS EN IEC 60947-3:2021 BS EN IEC 60947-1:2021			
Scope and classification fully covers the product (case 1 of Hager Group risk analysis) :	Yes			
Comments :	Designated After 2016			
Hager Group risk analysis: Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	DMS034433 followed using case 1 of Hager Group method: Designated Standard Used			

Table 1b Risk Assessment for Radio equipment		Applicable:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Hager Group risk assessment: Fill document DMS063155				

Evidence(s) / Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives

Certificate(s) / test report(s):	Intertek CB Test Certificate SE-112273 Intertek CB Test Report No 230200273SHA-001 Intertek Test Verification of Conformity 230200273SHA-V1 Intertek Test Verification of Conformity 230200273SHA-V2 LOVAG Certificate FR015-011 LOVAG Certificate FR015-012 LOVAG Certificate FR015-013
Mark approval(s):	None
Product documentation :	See Hager Website
Comments:	None

Signature (technical design)

Name of signatory

Thierry Lienhardt

Function of signatory

Enclosure Systems Product Engineering Director

Place and date of issue

Obernai, FR 21/12/2023

Signature



UKCA DECLARATION OF CONFORMITY

No. UKCA 23.3657.12.23

Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 60947-1:2007	Low-voltage switchgear and controlgear - Part 1: General rules	01/01/2021	0009/21
S.I. 2016 No. 1101	EN 60947-3:2009	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	01/01/2021	0009/21

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1091	EN 60947-1:2007	Low-voltage switchgear and controlgear - Part 1: General rules	01/01/2021	0007/21
S.I. 2016 No. 1091	EN 60947-3:2009	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	01/01/2021	0007/21

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------