





**(EN) Residual Current Circuit Breakers (RCCB's) 80 - 100A**



6C5026.d





**WARNING: installation by qualified contractors only.**




**Electrical connection for P + N for three phases only**




**Positive contact indication**




**TEST: test regularly RCCB must trip.**




**Two positions din rail clip**



### Sealable terminal cover



### Locking device for handle MZN175



### EN Warranty

A warranty period of 24 months is offered on Hager products, from date of manufacture, relating to any material of manufacturing defect.

If any product is found to be defective it must be returned via the installer and supplier (wholesaler).

The warranty is withdrawn if, after inspection by Hager quality control dept the device is found to have been installed in a manner which is contrary to IEE wiring regulations and accepted practice within the industry at the time of installation and/or the procedure for the return of goods has not been followed. Explanation of defect must be included when returning goods.



### Protection against dust

In case of work activities nearby, make sure that the electrical installation is protected against dust if the enclosure is not IP5x.